

Date Prepared 05/2001
Prepared By Carla McGreevy
Revised 6/14/05; 9/4/08 P Watt

BMP Physical Plant #1

TITLE: Aboveground Tank Monthly Inspections

Regulatory Citation: 6 NYCRR Part 374-3

Applicability: The following aboveground tanks must be inspected monthly:

Tank I.D.	Location
FZ 2- 550-gallon aboveground #2 fuel oil	Fitzgibbons
Wil-1 180-gallon aboveground #2 fuel oil + kerosene	Williams Heating & Refrigeration Department
HG-2 300 - gallon aboveground diesel	Higbee
GEN 2 400 gallon aboveground diesel	CoGen Plant
COG-1 385 gallon aboveground used oil	Cogan rm 153
LSB-1 2,000 gallon aboveground gasoline	Lapan Services Bldg
LSB-2 1,000 gallon aboveground diesel	Lapan Services Bldg

Purpose: Aboveground tanks and secondary containment structures must be inspected monthly for leaks and evidence of corrosion.

**Hudson Valley Community College
80 Vandenberg Avenue
Troy, NY 12180**

BULK PETROLEUM STORAGE