

Date Prepared 02/2006  
Revised 2/24/09 P Watt  
Prepared By Patty Watt

**BMP Physical Plant #4**

**TITLE:** Underground Tank Inspection

**Regulatory Citation:**

**Applicability:**

<b>Tank I.D.</b>	<b>Location</b>
HRC 1 5,000-gallon underground #2 Fuel Oil	To north of HRC
GEN 1 8,000 gallon underground diesel	North side of CoGen

**Purpose:** Inspection and maintenance of fill port overflow catch basin

**Department Responsible:** Stationary Engineers

**Schedule:** Once per week or after rain/snow events.

**Procedures:** The catch basin of each tank will be inspected and rain/snow melt removed. Remove water by sucking into a container and then emptying this container in to the oil water separator in the Grounds shop.

Do not use the tank drain in the basin to remove water – the sole purpose of this device is to drain fuel spills during delivery back into the tank.

**Record Location:** N/A

**Contact:**

Exec Mgr of Physical Plant (629-7427)  
Assistant to Exec Mgr 629-7361  
Director of Environmental, Health and Safety (629-7163)