

Date Prepared 05/2001
Revised 4/22/04, 9/17/08 P Watt
Prepared By Carla McGreevy

BMP Physical Plant #6

TITLE: Underground Tank Leak Detection

Regulatory Citation: 6 NYCRR Part 614.5(b)(3)

Applicability: The interstitial spaces of all USTs must be monitored once per week:

Tank I.D.	Location
HRC 1 5,000-gallon underground #2 Fuel Oil	To north of HRC
GEN 1 8,000 gallon underground diesel	North side of CoGen

Purpose: To detect tank leaks.

Department Responsible: Stationary Engineers

Schedule: